

बीसीजीवैक्सीनप्रयोगशाला / B C G VACCINE LABORATORY  
110, 33 फीटरोड, माउंटरोड /110, 33 Feet Road, Mount Road  
गिंडी / GUINDY, चेन्नई / CHENNAI 600032  
भारतसरकार / GOVERNMENT OF INDIA  
स्वास्थ्यसेवामहानिदेशालय / Directorate General of Health Services  
स्वास्थ्यऔरपरिवारकल्याणमंत्रालय / Ministry of Health & Family Welfare

No. D- 21034 / 07 /2017 – 18 (Stores)

dated 10 .01.2022

CORRIGENDUM

The following corrigendum to this office Tender No. D-21034/07/2017-18 (Stores) dated 22.12.2021 are hereby authorized:

Section III : Scope of Work - Add the following:

25. All the approvals (No Objection Certificate) have to be endorsed or renewed, if any required, will be within vendor's scope.
26. RS 485 provision – 1 No, to be provided to connect with BMS for taking print out of Diesel loaded / unloaded quantity by the Vendor.
27. Shed – 1 no, to be provided with GI sheets for the intermediate tank with necessary supports included in Vendors Scope.

This issues with the approval of Competent Authority.

  
(Dr. ANAND S.)  
VETERINARIAN

FOR DIRECTOR BCGVL